

# MEMO

**To:** Council  
**From:** Kyle Boudreau, Acting Chief Administrative Officer  
**Date:** January 6<sup>th</sup>, 2022  
**Re:** West Pubnico Lift Station Pump

---

On January 5<sup>th</sup>, 2022 we had 10 hp pump quit on us at our main pumping station in West Pubnico. This system operates with a 2-pump system that pumps in series. We have short-term installed a reused 5 hp to get us through the short term however this will eventually fail under this load.

The total cost of this pump replacement will be \$12943.77+ HST and will have a delivery time of 8 weeks. I am requesting funding outside of the West Pubnico Sewer Budget. The maintenance budget for this system is \$24,000 for the current budget year with \$16,392.62 used up as of Dec 31<sup>st</sup>, 2021.

I am requesting this be funded outside of the current budget parameters as the remaining maintenance budget will be needed to complete this budget year.

I have attached the quote which includes a 25% rebate being a return customer to this supplier.

Sincerely,

Kyle Boudreau  
Acting Chief Administrative Officer